


SMALL SCALE UL 263  
FIRE RESISTANCE TESTING  
FOR TPR<sup>2</sup> CORPORATION ON  
12 MILS OF FLEXIBLE FIRE SHELL  
INTUMESCENT COATING  
TESTED: JANUARY 23, 2006  
VTEC #100-2585-3



# VTEC Laboratories Inc.

June 14, 2007


**Client:** TPR<sup>2</sup> Corporation  
161 Interstate Lane  
Waterbury, CT 06705

**Attn:** Mr. Richard J. Barone Jr.

**Subject:** Fire Resistance Testing According to UL 263

**SAMPLE DESCRIPTION:** Wall Panel with 12 mils Flexible Fire Shell Intumescent Coating.

The 36"x36"x4.5" thick Gypsum wall panel was fabricated and coated by TPR<sup>2</sup> for UL 263 fire endurance testing. The wall was made up of 5 pieces of 2"x4" wood studs, 4 pieces forming a 36"x36" square frame and the fifth piece placed 18 inches from one side of the frame. One piece of 36"x36"x1/2" gypsum board was attached to each side of the frame using gypsum board screws. The cavity in the frame between the gypsum was filled with R-13 fiberglass wall insulation. The Flexible Fire Shell Intumescent Coating was applied to both surfaces of the gypsum wall at an average thickness of 12 mils dry. The wall panel was oriented so that the center stud was vertical.



**PROCEDURE:**

The furnace used in this test measures 3ft x 3ft x 3ft. The outside construction is steel and the furnace is lined with a ceramic refractory insulation. The furnace dimensions inside the insulation are nominally 27" x 27" x 27".

A single burner is centered vertically in the wall opposite the sample. This burner is rated for 1.5 million Btu/hr and is of the flat flame or non-impinging flame design. Furnace conditions are monitored by three Inconel-sheathed chromel-alumel thermocouples. These thermocouples are positioned 6" from the face of the sample.

The sample was oriented vertically in the front opening of the furnace. The unexposed surface temperature of the sample was monitored by six, 20-gauge type K, fiberglass sheathed thermocouples. An insulating pad was placed over each thermocouple on the unexposed side of the sample.

The fire test was run following the UL263 time-temperature curve.

The endpoint for the UL 263 test occurs when either all the thermocouples on the sample reach an average of 250°F + ambient starting temperature, any individual thermocouple on the sample exceeds 325 °F + ambient starting temperature, or when the sample experiences burn-through.

**RESULTS:**

The ambient temperature was 71°F.


At 52 minutes the coating on the unexposed side started bubbling. At 57 minutes smoke began to emit from the bottom of the sample.

At 62 minutes thermocouples #6 and #3 exceeded 396 °F and the average for all six thermocouples on the unexposed side exceeded 321 °F thus indicating failure.

The time-temperature data are contained on the following pages.



Neil Schultz  
Executive Director



Amirudin Rahim  
Technical Director

**DISCLAIMER:** This test should be used to measure and describe the properties of materials, products or assemblies in response to heat and flame under controlled laboratory conditions and should not be used to describe or appraise the fire hazards or fire risks of materials, products or assemblies under actual fire conditions. However, results of this test may be used as elements of a fire risk assessment, which takes into account all of the factors that are pertinent to an assessment of fire hazard of a particular end use.

**Notice:** VTEC Laboratories Inc. will not be liable for any loss or damage resulting from the use of the data in this report, in excess of the invoice. This report pertains to the sample tested only. Such report shall not be interpreted to be a warranty, either expressed or implied as to the suitability or fitness of said sample for such uses or applications, as the party contracting for the report may apply such sample.

Time (mins.)	Sample 1 deg F	Sample 2 deg F	Sample 3 deg F	Sample 4 deg F	Sample 5 deg F	Sample 6 deg F	Furnace deg F	Furnace deg F	Furnace deg F	Sample Average	Furnace Average
0	71	71	70	70	72	70	56	58	58	71	57
1	71	71	70	70	72	70	555	576	620	71	584
2	71	71	70	70	72	70	639	651	662	71	651
3	71	71	70	70	72	70	784	807	833	71	808
4	71	71	70	70	72	70	829	862	887	71	859
5	71	71	70	70	72	70	893	940	984	71	939
6	71	71	70	70	72	70	991	1032	1077	71	1034
7	71	71	70	70	72	70	1076	1117	1156	71	1116
8	71	71	70	70	72	70	1137	1157	1197	71	1164
9	71	71	74	72	72	72	1274	1248	1222	72	1248
10	73	72	82	79	72	79	1311	1300	1265	76	1292
11	79	75	96	90	73	92	1320	1335	1360	84	1336
12	90	81	116	106	76	109	1321	1345	1371	96	1346
13	105	90	136	125	80	127	1328	1357	1398	110	1361
14	123	100	156	144	85	144	1336	1363	1412	125	1370
15	141	110	172	160	92	159	1347	1378	1414	139	1379
16	157	121	183	173	98	171	1349	1414	1421	150	1394
17	171	131	191	184	105	180	1373	1433	1429	160	1412
18	181	139	198	192	111	188	1388	1465	1460	168	1437
19	189	147	204	198	117	194	1437	1496	1505	175	1479
20	197	154	209	204	122	199	1442	1498	1510	181	1483
21	202	160	213	209	127	203	1447	1501	1511	186	1486
22	207	165	216	213	131	206	1459	1502	1512	190	1491
23	211	170	218	215	135	208	1461	1503	1514	193	1496
24	214	173	218	216	138	208	1469	1531	1531	194	1510
25	214	176	216	215	141	207	1472	1532	1533	195	1512
26	214	177	215	213	144	206	1472	1533	1536	195	1514
27	213	179	213	212	146	204	1488	1551	1556	194	1532
28	212	179	212	210	147	202	1506	1560	1558	194	1541
29	211	179	209	207	148	199	1514	1563	1559	192	1545
30	208	179	207	205	149	196	1522	1565	1565	191	1551
31	202	177	199	200	148	195	1527	1574	1580	187	1560
32	203	178	200	200	150	193	1533	1581	1586	187	1567
33	203	178	200	201	152	193	1537	1585	1589	188	1570
34	202	179	201	201	153	194	1541	1588	1596	188	1575
35	202	180	202	203	155	195	1543	1590	1597	190	1577
36	202	180	206	205	156	197	1553	1598	1608	191	1586
37	203	181	209	208	157	199	1565	1628	1634	193	1609
38	204	182	212	211	159	202	1572	1632	1638	195	1614
39	206	182	216	214	160	206	1582	1649	1644	197	1626
40	208	183	221	217	161	210	1590	1650	1647	200	1629
41	210	185	226	221	162	215	1595	1652	1650	203	1632
42	213	186	231	225	163	221	1596	1653	1651	206	1633